

Wey Valves	Lubricants applied by Sistag	Notes
WEY KNIFE GATE VALVES		
<i>Seals</i>		
– NBR		
– EPDM	– Silicone grease	EPDM must not be in contact with mineral oil containing lubricants. For potable water applications an adequate approval is necessary. ¹
– FPM	– Berulub SIHAF 2	
– AFLAS	– Alternative: Paraliq GTE 703	
<hr/>		
<i>Manual actuation</i>		
Stem / Stem nut	ASEOL Calwares C2	
<hr/>		
Bearing points	ASEOL Calwares C2	
<hr/>		
<i>Cylinder</i>		
Piston seal / Cylinder barrel	TCE-Grease 130 (Bechem High Lub LFB 2000)	
Piston rod seal / Piston rod	TCE-Grease 130 (Bechem High Lub LFB 2000)	
<hr/>		
<i>Electric actuation / Gear box</i> AUMA	AUMA grease (Art. No. K 000.001)	
<hr/>		
Stem bearing	Klüber Microlube GBUY 131	
<hr/>		
Stem / Stem nut	ASEOL Calwares C2	
<hr/>		
Stainless steel screws	MI-setral-5B	
<hr/>		
WEY SLUICE GATES		
<i>Seal</i> NBR	Klüber Microlube GBUY 131	Alternative: ASEOL Calwares C2 (Exceptions: Ball bearings, AUMA gear boxes)
<hr/>		
<i>Manual actuation</i>		
Stem / Stem nut	Klüber Microlube GBUY 131	EPDM must not be in contact with mineral oil containing lubricants. For potable water applications an adequate approval is necessary. ¹
Bearing points / ball bearings	Klüber Microlube GBUY 131	
<hr/>		
<i>Cylinder</i>		
Piston seal / Cylinder barrel	Klüber Microlube GBUY 131	
Piston rod seal / piston rod	Klüber Microlube GBUY 131	
<hr/>		
<i>Electric actuation / gear box</i> AUMA	AUMA grease (Art. Nr. K 000.001)	
<hr/>		
Stem bearing	Klüber Microlube GBUY 131	
<hr/>		
Stem / Stem nut	Klüber Microlube GBUY 131	
<hr/>		
Stainless steel screws	MI-setral-5B	
<hr/>		
WEY BUTTERFLY AND CHECK VALVES TZ / TK		
<i>Seal</i> EPDM	Klübersynth VR69-252	
<hr/>		
<i>Pivoting parts</i>		
Shaft / Bearings	Klübersynth VR69-252	EPDM must not be in contact with mineral oil containing lubricants. For potable water applications an adequate approval is necessary. ¹
O-rings	Klübersynth VR69-252	
<hr/>		
Stainless steel screws	MI-setral-5B	
<hr/>		
WEY CHECK VALVES RSK		
<i>Seal</i> NBR	–	EPDM must not be in contact with mineral oil containing lubricants. For potable water applications an adequate approval is necessary. ¹
<hr/>		
<i>Pivoting parts</i>		
Shaft / bearings	Klübersynth VR69-252	
O-rings	Klübersynth VR69-252	
<hr/>		
Stainless steel screws	MI-setral-5B	

¹ For food applications specific lubricants with adequate approvals should be used.